



Interstate Brick
West Jordan, UT
Executive Summary
Project No. 2511-01

Six types of clay brick were submitted to AMT Laboratories by PROSOCO, Inc. with a request to determine the most appropriate new construction cleaner. Additionally, water repellent and graffiti resistant products suitable for clay brick were evaluated.

The laboratory report (2511-01 PTP Interstate Brick) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as photographs, conclusions, and recommendations. Recommendations are also provided in the chart below.

Recommendations:

| Sample | New Construction Cleaning | Water Repellency | Graffiti Resistance |
|-----------------------|--|--|---|
| "Black Ice" Brick | ¹ Sure Klean® Vana Trol® (1:6) or (1:8) OR ² Sure Klean® 600 (1:6) or (1:8) OR ² Enviro Klean® Safety Klean (1:2) or (1:3) | Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 6 OR Sure Klean® Weather Seal Siloxane WB Concentrate (1:9) OR Sure Klean® Weather Seal Siloxane PD | <u>Graffiti Repellents</u> Sure Klean® Weather Seal Blok-Guard® & Graffiti Control WB 6 <u>Graffiti Removers</u> Sure Klean® Graffiti Remover OR Enviro Klean® SafStrip® |
| "Columbard" Brick | | | |
| "Dartmouth" Brick | | | |
| "English Tudor" Brick | | | |
| "Old Virginia" Brick | | | |
| "Mocha" Brick | | | |

NOTE: "1" indicates the recommended first choice and "2" indicates the recommended second choice. These recommendations are also based on the Product Data Sheet limitations for certain brick types.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.