



SiteOne – Solstice Stone
Roswell, GA
Executive Summary
Project No. 2608-01

Eleven types of natural stone were submitted to AMT Laboratories by PROSOCO, Inc. with a request for adverse effects testing. Additionally, color and sheen enhancement and water repellent products suitable for the natural stone were evaluated.

The laboratory report (2608-01 PTP SiteOne – Solstice Stone) provides information about the PROSOCO® products tested and descriptions of the test methods. The report includes test results as well as conclusions and recommendations. Recommendations are also provided in the chart below.

Recommendations:

Sample	Adverse Effects	Color and Sheen Enhancement	Water Repellency
“Diana Royal” Marble	Enviro Klean® 2010 All Surface Cleaner (1:10) OR Enviro Klean® Klean ‘N Release Cleaner (1:10)	Please refer to pages 18-31 of the report for individual recommendations based on the desired result.	Sure Klean® Weather Seal Natural Stone Treatment WB OR Sure Klean® Weather Seal Color Enhancer WB
“Ice White” Marble			
“Tundra Gray” Marble			
“Ivory” Travertine			
“Silver” Travertine			
“Walnut” Travertine			

NOTE: “1” indicates the recommended first choice and “2” indicates the recommended second choice.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.



SiteOne – Solstice Stone
Roswell, GA
Executive Summary
 Project No. 2608-01

Recommendations: (cont.)

Sample	Adverse Effects	Color and Sheen Enhancement	Water Repellency
"Shellstone" Limestone	Enviro Klean® 2010 All Surface Cleaner (1:10) OR Enviro Klean® Klean 'N Release Cleaner (1:10)	Please refer to pages 18-31 of the report for individual recommendations based on the desired result.	¹ Sure Klean® Weather Seal Natural Stone Treatment WB OR ² Sure Klean® Weather Seal Color Enhancer WB
"SW Black" Limestone			Sure Klean® Weather Seal Natural Stone Treatment WB OR Sure Klean® Weather Seal Color Enhancer WB
"SW Buff" Sandstone			
"SW Grey" Sandstone			
"SW Tan" Sandstone			

NOTE: "1" indicates the recommended first choice and "2" indicates the recommended second choice.

Apply all products in accordance with the manufacturer's recommendation provided on container labels and product data sheets. On-site testing should be conducted to determine the most appropriate product and procedures for a particular project. See product literature for additional application and product information.