



Architectural Testing

## LETTER OF RESULTS

**Letter Issued To:** PROSOCO  
3741 Greenway Circle  
Lawrence, KS 66046

**Test Laboratory:** Architectural Testing, Inc.  
22155 68<sup>th</sup> Ave. South  
Kent, WA 98032  
253-395-5656

### Project Summary:

**Product Type:** Air Barrier Wall Assembly

**Products Tested:** Prosoco R-Guard Cat 5, Fast Flash, Joint & Seam Filler, & Air Dam Sealant.

**Test Dates:** 01/23/2012 - 01/31/2012

**Findings/Compliance Statement:** The products tested met the requirements of ASTM E 2357-05, *Standard Test Method for Determining Air Leakage of Air Barrier Assemblies*. Results obtained are tested values and were secured by using the designated test method(s). The mock-ups tested were representative of target installation methods. Testing was performed on one controlled wall and one penetrated wall.

For additional information reference Architectural Testing, Inc report A8501.01-901-44. The service life of this report will expire on the stated Test Record Retention End Date, at which time such materials as drawings, data sheets, samples of test specimens, copies of this report, and any other pertinent project documentation, shall be discarded without notice.

For,

ARCHITECTURAL TESTING, INC.

Jeffrey L. Dideon  
Director – Regional Operations

JLD:pac