

**SCS Global Services** does hereby certify that an independent assessment has been conducted on behalf of:

## PROSOCO, Inc.

3741 Greenway Circle, Lawrence, KS, United States

For the following product(s):

### Sealants and Sealant Coatings:

AirDam<sup>®</sup>, Joint & Seam Filler, R-Guard Cat 5, R-Guard Cat 5 Rain Screen, R-GUARD<sup>®</sup> FastFlash<sup>®</sup>, R-Guard<sup>®</sup> Fast-Flash<sup>®</sup> (Roller-Grade), R-Guard<sup>®</sup> PorousPrep

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

### Indoor Advantage™ Gold

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method (CA 01350) v1.2-2017 for the school classroom, private office, and single-family residence parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (January 2005), or CARB SCM 2007, as applicable.

Average Product Application Amount: 12.5 g/m<sup>2</sup>

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m<sup>3</sup> (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Registration # SCS-IAQ-03372

Valid from: January 1, 2019 to December 31, 2019



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Vice President  
SCS Global Services  
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA